



IIS/ADMIN/042/2024-25

Date – 15/01/2025

Letter of Enquiry – Fire & safety maintenance work

We would like to request you to send us the quotation for **Fire & safety maintenance work** for our school buildings with the following specifications. Please quote the competing price and service time for the following.

Sr.	Description	Qty	Unit
Girls Section			
1	Supply and replacement of Hose Nylon. Single Jacket. 1.5" X 30 Meters. White Color. With 1.5" NST Aluminum Coupling	Ea	2
2	Supply and replacement of angle valve 1.5"	Ea	2
3	Supply and replacement of Nozzle. Jet Type. 1.5".	Ea	2
4	Removing jockey pumps for deeply inspection	Ea	1
5	Supply and replacement of conventional manual call point	Ea	8
Main Building			
1	Supply and replacement of conventional fore alarm control panel 16 zones including power supply and batteries at main building	Ea	1
2	Supply and install simplex addressable 4007 es panel with backup batteries at main building	Ea	1
3	Programing for simplex addressable 4007es panel (Security Room and main building)	Ea	2
4	Supply and install simplex addressable monitor modules including wiring, piping and needed accessories at main building	Ea	2
5	Supply and install simplex addressable control modules including wiring, piping and needed accessories at main building	Ea	2
6	Supply and replacement of conventional manual call point	Ea	10
7	Repairing firefighting water leakage with Needed accessories ,fittings and consumable material.	Ea	1
8	Supply and replacement of Hose Nylon. Single Jacket. 1.5" X 30 Meters. White Color. With 1.5" NST Aluminum Coupling	Ea	1
Junior Primary School			
1	Supply and replacement of Hose Nylon. Single Jacket. 1.5" X 30 Meters. White Color. With 1.5" NST Aluminum Coupling	Ea	2
2	Supply and replacement of batteries 12V,7Ah	Ea	2
KG Section			
1	Supply and replacement of Hose Nylon. Single Jacket. 1.5" X 30 Meters. White Color. With 1.5" NST Aluminum Coupling	Ea	1
2	Removing jockey pumps for deeply inspection at primary school	Ea	1
3	Supply and replacement of conventional manual call point	Ea	2
4	Repairing firefighting water leakage with Needed accessories ,fittings and consumable material.	Ea	1



INTERNATIONAL INDIAN SCHOOL - AL JUBAIL

Eastern Province - Kingdom of Saudi Arabia
Licenced By Ministry of Education K.S.A. Vide Lic. No. Jeem - 5
Affiliated to Central Board of Secondary Education
Delhi, India. Affin. No. 5730007 - School No. 90002
E-mail: Info@iisjubail.org
VAT. 310156908100003



المدرسة العالمية الهندية - الجبيل

المنطقة الشرقية - المملكة العربية السعودية
تصريح وزارة التعليم بالمملكة العربية السعودية رقم ج - ٥
بالتعاون مع مجموعة الوسط للتعليم الثانوي
دلهي الهند، رقم ٥٧٣٠٠٠٧ - مدرسة رقم ٩٠٠٠٢
Website: www.iisjubail.org

Notes:

1. Sealed Quotation should be dropped in the box provided at the designated place in the admin office during office hours (08:00 am to 02:30 pm) on or before 19th January 2025.
2. Quotation should be addressed in the name of Principal IIS Jubail.
3. *For further information and site visit, please feel free to contact, Mob – 0555025435/ 0555021095, Tel – 013 362 4130 Ext-267/242/226.*

Thanks & regards

Sl 3 15/1/2025
Admin Officer
IIS Jubail, KSA

